

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Mukesh Kumar (A.E.)

(Name of Officers with designation) from Uttarakhand Jal Sansthan PHED Uthman Singh Nagar

inspected the Dav Public School, Shimla Pictam Rudrapur

(Name & Address of the school) on 2-5-25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 21/USJ/DLWQTMH/2025-2026 dated 31-5-25

of D.L.W.Q.T.M.L.U.S. (PHED Lab) certified that the


Rudrapur Uthman Singh Nagar (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal: 

Name

Designation

Name & Address of the Office/ Department

सहायक अभियन्ता (मु०)

उत्तराखण्ड जल संस्थान

रुद्रपुर

To Dav Public School
Shimla Pictam Rudrapur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Rudrapur U.S. Nagar

E-mail: eeudmujs@gmail.com

Test Report ID: 21/UJS/DLWQTML/2025-26

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	DAV PUBLIC SCHOOL, Shimla Pistaù, Lalpur, Rudrapur, Distt-U.S.Nagar		
Type of Source (Drinking Water/ Ground Water/ Sub-Surface Water)	Sample Description: Drinking Water	One water Sample collected from school campus submerisable	
Reference Sample Identification:	DLWQTML/UJS/DAV-01	Date of Start of Analysis: 30.05.2025	
		Date of End of Analysis : 31.05.2025	
Date of Sample Received: 30.05.2025		Sample Collected by:	Customer

SN	Parameters	Test Method	Result	Requirement Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11) 2022,	7.42	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C	IS 3025 (Part 16), 2023	165	500 Max	2000 Max
3.	Turbidity, NTU	IS 3025 (Part 10), 2023	0.51	1 Max	5 Max
4.	Total Alkalinity (as CaCO ₃), mg/l	IS 3025 (Part 23), 2023	121	200 Max	600 Max
5.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	118	200 Max	600 Max
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	32.8	75 Max	200 Max
7.	Chloride, mg/L	IS 3025 (Part 32), 2019	15.0	250 Max	1000 Max
8.	Magnesium as Mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	8.74	30 Max	100 Max
9.	Colour, Hazen	IS 3025 (Part 4): 2021	Less than 5	5 Max	15 Max
10.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable
11.	E.Coli, MPN/ 100 ml	APHA 23 rd Ed.-9223-B	Absent	Absent	Absent
12.	Total Coliform, MPN/100ml	APHA 23 rd Ed.-9223-B	Absent	Absent	Absent

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.


Chemist


Lab Incharge/Quality Manager

उत्तराखण्ड जल संस्थान
ऊधम सिंह नगर

-End of Report-